

FLASH SUPPRESSOR 2" (F)

Part No
29150

TECHNICAL DATA

FLASH SUPPRESSOR 2" (F)

Installed on the vent pipe from the tank. Should be checked once a year. According to the authorities, it is a requirement for all tanks with flammable goods.

TECHNICAL DATA

Part No	29150
H.S. Code	84212980